



City of Phoenix
Water Services Department

Date: April 4, 2012

Case: 12-08

To: MAG Specification & Details Committee

From : Jami Erickson

RE: Section 611 Disinfecting Water Mains

Purpose: Modify Section 611.17 to include a refreshing plan to assure safe water quality and to document the expectation by the Owner on maintaining the pipeline fresh until after final acceptance has been granted.

Revisions:

611.17 REFRESHING PLAN:

The Contractor shall submit a refreshing plan including procedures, responsibilities and locations for keeping lines fresh after testing, chlorination but prior to final acceptance of main. Water in the pipe shall be completely flushed and turned over at least every 10 calendar days. The Contractor shall obtain and maintain any permits and flushing logs required for this activity.

611.18 PAYMENT:

No separate pay item shall be contained in the proposal for disinfecting water mains. This operation shall be included in the price bid for the water mains, installed complete in place, as specified in the proposal.

Deleted: 611.17