

Case 09-04 – Modified Section 322: Add Pavement Fabric Interlayer for AC Overlay

Comments from 4/1/09 Meeting:

1. Determine how this case can be incorporated into Section 321 since it is anticipated that Section 322 will be merged into 321 in the near future.

Response: Section 322 – as it exists today – can be made part of Section 321 by including a new subsection 321.5.6 titled “Asphalt Concrete Overlay”. This new subsection would include all paragraphs of Sections 322.1 through 322.6, with minor tweaking of the language. The proposed fabric interlayer section (this case) could then become new subsection 321.8.7 titled “Pavement Fabric Interlayer,” with no changes needed in the proposed language.

That said, it is recommended that this case proceed as presented since it is out of the scope of the case to merge all components into Section 321. A case later this year or next year could be presented that is exclusive of the intent of this case.

2. Provide specific instructions noting that interlayer use at the option of the agency.

Response: Agreed. See the first paragraph in the revised version.

3. Note that the interlayer will not result in a reduced pavement section.

Response: Agreed. See the first paragraph in the revised version.

Written comments by City of Mesa:

In the 2nd sentence of the sixth paragraph of Section 322.4, “...is not be allowed” should be changed to “...is not allowed” or “...is not to be allowed”.

Response: Agreed. Typo corrected.