



MEMORANDUM

Case # 20-02

DATE: February 24, 2020

TO: MAG Specifications and Details Committee Members

FROM: Warren White, City of Chandler Representative

SUBJECT: Proposed Removal of Detail 346 Fireline Detector Check Vault

This standard detail was last revised in 1998 and is no longer in use. Fire line double check detectors are now installed above ground and typically placed outside of the public rights-of-way on the private fire line. Given this detail is out-of-date to current practice and not used by agencies recommendation is removal.

